ANGELINA COLLEGE SAFETY-SHOWER/EYE WASH INSPECTION INSTRUCTIONS	
NO. El-03 6.3.a	**TITLE:** Safety Shower/ Eye Wash Inspection Instructions **PAGE** 1 **of** 1 **ISSUED:** 10/15 **REVISED:** 6/27

NOTES:

- Eye washes must be tested and inspected weekly.
- An Eye Wash Inspection Tag will be attached to each eye wash.
- ***Outlet heads (lids covering where water flows from) should be kept closed when not in use***

INSTRUCTIONS:

- Run the eye wash for 2-3 minutes, ensuring:
  - there is sufficient water flow
  - the hands-free mechanism is functioning
- Initial the appropriate box on the attached Inspection Tag to document a passing inspection
- If inspection fails, notify all users and call Campus Services: 633-5280 for repairs

- **Should an exposure occur, flush the affected eye(s) for 15 minutes.**
- **To ensure adequate flushing, hold eyelid(s) open and roll the eyeball.**

INSPECTION TAGS			
Date of Inspection	**Initials of Person Testing**	**Date of Inspection**	**Initials of Person Testing**