ANGELINA COLLEGE SAFETY-SHOWER/EYE WASH INSPECTION INSTRUCTIONS	
NO. El-03 6.3.a	**TITLE:** Safety Shower/Eye Wash Inspection **PAGE** 1 **of** 1 **ISSUED:** 10/2015 **REVISED:** 03/2026

NOTES:

- Eye washes must be tested and inspected weekly.
- An Eye Wash Inspection Tag will be attached to each eye wash.
- ***Outlet heads (lids covering where water flows from) should be kept closed when not in use***

INSTRUCTIONS:

- Run the eye wash for 2-3 minutes, ensuring:
  - There is sufficient water flow
  - The hands-free mechanism is functioning
- Initial the appropriate box on the attached Inspection Tag to document a passing inspection
- If inspection fails, notify all users and call Campus Services: (936) 633-5280 for repairs

- **Should an exposure occur, flush the affected eye(s) for 15 minutes.**
- **To ensure adequate flushing, hold eyelid(s) open and roll the eyeball.**

INSPECTION TAGS			
Date of Inspection	**Initials of Person Testing**	**Date of Inspection**	**Initials of Person Testing**